

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 049

Dated 17/05/2025

It is certified that an inspection team headed by Devesh Chandra (Chemist), P.H. Division Biharsharif from P.H.E.D Nalanda inspected the Daffodil Public School, Shri Satisthan Mangalasthan Road, Biharsharif Nalanda on 16/05/2025 and found that the Daffodil Public School Shri Satisthan Mangalasthan Road Biharsharif Nalanda has safe drinking water facilities for the student and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for the period of 01(One) Year.

Signature with seal : 

Name : Er. Raghevendra Kumar

Designation : Executive Engineer

*Executive Engineer
P.H. Division
Biharsharif*

To,

Daffodil Public School
Shri Satisthan Mangalasthan Road
Biharsharif, Nalanda
(Name & Address of Institution)

Government of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department, Nalanda

Ref.No. SE-1358 dt. -17-05-2025

Date of Sampling -16-05-2025

Name of Institute :- Daffodil Public School Sample Collected By- PHED Staff
Shri Satisthan Mangalasthan Road, Biharsharif Nalanda Bihar
Source of Sample - Ground water

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No	Physio – Chemical and Bacteriological Parameters																	Remar k		
	Block	Panchayat	Village	Habitation	Name	pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO2	SO4	F	As	Micro bial
1		Daffodil Public School Biharsharif Nalanda Bihar				7.12	1.35	285.3	298.5	103.7	55.8	29.5	38.3	95.6	0.5	5.65	19.5	1.45	BDL	NT
		Desirable Limit*	6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-			
		Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**			

Remark: Analyzed Water Sample is Safe For Drinking Purpose.

Copy Forwarded To :I, Executive Engineer, P.H.Division Nalanda Bihar, for kind information and necessary action.



Lab. Assistant


Chemist 17/5/25